

**SINGLE FAMILY SERVICE LOAD CALCULATIONS
BASED ON THE 2014 NEC SECTION 220.82**

GENERAL LOADS NEC 220.82(B)

TOTAL SQ FOOTAGE (1,500 SQ FT X 3 VA) = 4,500 VA
 APPLIANCE CIRCUITS (2 X 1,500 VA) = 3,000 VA
 LAUNDRY CIRCUITS (1 X 1,500 VA) = 1,500 VA

RANGE (2 ON ANY 2 PHASES) = 24,000 KVA
 PER PHASE DEMAND (24,000 VA ÷ 2) = 12,000 VA
 EQUIVALENT 3-PHASE LOAD (12,000 VA X 3) = 36,000 VA

DRYER (2 ON ANY 2 PHASES) = 10,000 KVA
 PER PHASE DEMAND (10,000 VA ÷ 2) = 5,000 VA
 EQUIVALENT 3-PHASE LOAD (5,000 VA X 3) = 15,000 VA

WATER HEATERS (1 X 2,500 VA) = 2,500 VA

MISC LOADS NEC 220.82(B)(4)

DISHWASHER (1 X 10A X 120 V) = 1,200 VA

**PROJECT NAME
DWELLING UNIT**

**SAMPLE
DP**

NEUTRAL LOAD NEC 220.61

TOTAL SQ FOOTAGE (1,500 SQ FT X 3 VA) = 4,500 VA
 APPLIANCE CIRCUITS (2 X 1,500 VA) = 3,000 VA
 LAUNDRY CIRCUITS (1 X 1,500 VA) = 1,500 VA
 TOTAL CONNECTED NEUTRAL LOAD = 9,000 VA

FIRST 3,000 VA @ 100% (3,000 VA X 1.00) = 3,000 VA
 3,000-120,000 VA @ 35% (6,000 VA X 0.35) = 2,100 VA
 OVER 120,000 VA @ 25% (0 VA X 0.25) = 0 VA
 SUBTOTAL = 5,100 VA

RANGE DEMAND NEC 220.61
 PROHIBITED REDUCTION NEC 220.61(C)(1)
 100% OF TABLE 220.55 (8,000 VA X 1.00) = 8,000 VA

DRYER DEMAND NEC 220.61
 PROHIBITED REDUCTION NEC 220.61(C)(1)
 100% OF TABLE 220.54 (5,000 VA 1.00 VA X 1.00) = 5,000 VA

UNBALANCED MISC LOADS = 1,200 VA

NEUTRAL LOAD VA = 19,300 VA

NEUTRAL LOAD (19,300 VA ÷ 1.732 ÷ 240 V) = 46 A

FURTHER DEMAND FACTOR - 2005 NEC 220.61(B)(2)
 FIRST 200 A @ 100% (46 A X 1.00) = 46 A
 REMAINDER @ 70% (0 A X 0.70) = 0 A

MINIMUM NEUTRAL CONDUCTOR AMPACITY = 46 A

VOLTAGE DROP CALCULATIONS

(2 X 50' L X 0.2530 R X 84.0 A ÷ 1,000 X 0.866) = 1.8 VD
 (1.8 VD ÷ 240 V X 100) = 0.8 % VD

FAULT CURRENT CALCULATIONS

((28,875 AFC X 1.00 UA) + 0 MC) = 28,875 AFC
 (1.732 X 50 L X 28,875 AFC) ÷ (4,699 C X 1 N X 240 V) = 2.217 CF
 (1) ÷ (1 + 2.217 CF) = 0.311 CM
 (28,875 AFC X 0.311 CM) = 8,980 CLC

TOTAL GENERAL LOAD = 63,700 VA
 FIRST 10 KVA AT 100% = 10,000 VA
 REMAINDER OF LOAD AT 40% = 21,480 VA
 SUB TOTAL GENERAL LOAD = 31,480 VA

HEATING & COOLING LOADS - NEC 220.82(C)

(1) AC LOAD (0 VA X 100%) = 0 VA
 (2) HEAT PUMPS NO SUPP (0 VA X 100%) = 0 VA
 (3) ELECTRIC CONTINUOUS (0 VA X 100%) = 0 VA
 (4) HEAT PUMPS WITH SUPPL (0 VA X 100%) = 0 VA
 (5) SPACE HEATING (0 VA X 65%) = 0 VA
 (6) SPACE HEATING (9,000 VA X 40%) = 9,000 VA
 LARGEST HEATING OR COOLING LOAD = 3,600 VA
 TOTAL KVA = 35,080 VA

TOTAL AMPS (35,080 VA ÷ 1.732 ÷ 240 V) = 84 A
 FUTURE AMPS (0%) = 0 A
 DESIGN AMPS = 84 A

KEY
 (N) - Neutral
 A - Amps
 L - Length
 R - Resistance
 V - Volts
 VA - Volt Amps

VD - Voltage Drop

