

**SINGLE FAMILY SERVICE LOAD CALCULATIONS
BASED ON THE 2008 NEC SECTION 220.82**

GENERAL LOADS NEC 220.82(B)

TOTAL SQ FOOTAGE (1,500 SQ FT X 3 VA) = 4,500 VA
 APPLIANCE CIRCUITS (2 X 1,500 VA) = 3,000 VA
 LAUNDRY CIRCUITS (1 X 1,500 VA) = 1,500 VA

RANGES (2 RANGES X 12,000 VA) = 24,000 VA

DRYER (1 DRYER X 5,000 VA) = 5,000 VA

WATER HEATERS (1 X 2,500 VA) = 2,500 VA

MISC LOADS NEC 220.82(B)(4)

DISHWASHER (1 X 10A X 120 V) = 1,200 VA

TOTAL GENERAL LOAD 41,700 VA
 FIRST 10 KVA AT 100% 10,000 VA
 REMAINDER OF LOAD AT 40% 12,680 VA
 SUB TOTAL GENERAL LOAD 22,680 VA

HEATING & COOLING LOADS - NEC 220.82(C)

(1) AC LOAD (5,000 VA X 100%) = 5,000 VA << LARGEST

(2) HEAT PUMPS NO SUPP (0 VA X 100%) = 0 VA

(3) HEAT PUMPS (0 VA X 100%) = 0 VA

SUPPLEMENTAL HEAT (0 VA X 65%) = 0 VA

(4) ELECTRIC SPACE (0 VA X 65%) = 0 VA

LESS THAN FOUR SEPARATELY CONTROLLED UNITS.

(5) SPACE HEATING (12,000 VA X 40%) = 4,800 VA

MORE THAN FOUR SEPARATELY CONTROLLED UNITS.

(6) SPACE HEATING (0 VA X 100%) = 0 VA

CONTINUOUS AT THE FULL NAMEPLATE VALUE.

LARGEST HEATING OR COOLING LOAD 5,000 VA

TOTAL KVA 27,680 VA

TOTAL AMPS (27,680 VA ÷ 240 V) = 115 A

FUTURE AMPS (0%) 0 A

DESIGN AMPS 115 A

- | | | | |
|------------|-------------------------------|-------------------------------------|--------------------------|
| KEY | (N) - Neutral | CLC - Conductor Let Through Current | N - Number of Conductors |
| | A - Amps | CM - Conductor Multiplier | R - Resistance |
| | AFC - Available Fault Current | CU - Copper | UA - Utility Adjustment |
| | AL - Aluminum | GND - Ground | V - Volts |
| | C - Conductor Constance | L - Length | VA - Volt Amps |
| | CF - Conductor Factor | MC - Motor Contribution | VD - Voltage Drop |

**PROJECT NAME
DWELLING UNIT**

SAMPLE
DP1

NEUTRAL LOAD NEC 220.61

TOTAL SQ FOOTAGE (1,500 SQ FT X 3 VA) = 4,500 VA
 APPLIANCE CIRCUITS (2 X 1,500 VA) = 3,000 VA
 LAUNDRY CIRCUITS (1 X 1,500 VA) = 1,500 VA
 TOTAL CONNECTED NEUTRAL LOAD 9,000 VA

FIRST 3,000 VA @ 100% (3,000 VA X 1.00) = 3,000 VA
 3,000-120,000 VA @ 35% (6,000 VA X 0.35) = 2,100 VA
 OVER 120,000 VA @ 25% (0 VA X 0.25) = 0 VA
 SUBTOTAL 5,100 VA

RANGE DEMAND

TABLE 220.55 COLUMN C
 70% OF TABLE 220.55 (11,000 VA X 0.70) = 7,700 VA

DRYER DEMAND

TABLE 220.54
 70% OF TABLE 220.54 (5,000 VA 1.00 VA X 0.70) = 3,500 VA

UNBALANCED MISC LOADS 1,200 VA

NEUTRAL LOAD VA 17,500 VA

NEUTRAL LOAD (17,500 VA ÷ 240 V) = 73 A

FURTHER DEMAND FACTOR - 2005 NEC 220.61(B)(2)

FIRST 200 A @ 100% (73 A X 1.00) = 73 A
 REMAINDER @ 70% (0 A X 0.70) = 0 A

MINIMUM NEUTRAL CONDUCTOR AMPACITY 73 A

VOLTAGE DROP CALCULATIONS

(2 X 10' L X 0.2010 R X 115.0 A ÷ 1,000) = 0.5 VD

(0.5 VD ÷ 240 V X 100) = 0.2 % VD


FAULT CURRENT CALCULATIONS

((14,000 AFC X 1.00 UA) + 0 MC) = 14,000 AFC

(2 X 10 L X 14,000 AFC) ÷ (5,777 C X 1 N X 240 V) = 0.202 CF

(1) ÷ (1 + 0.202 CF) = 0.832 CM

(14,000 AFC X 0.832 CM) = 11,648 CLC



FEEDER PER TABLE 310.15(B)(6)