

**SINGLE FAMILY SERVICE LOAD CALCULATIONS
BASED ON THE 2023 NEC SECTION 220.82**

PROJECT NAME SAMPLE
PANEL NAME MAIN PANEL

GENERAL LOADS NEC 220.82(B)

TOTAL SQ FOOTAGE (1,500 SQ FT X 3 VA) = 4,500 VA
 APPLIANCE CIRCUITS (2 X 1,500 VA) = 3,000 VA
 LAUNDRY CIRCUITS (1 X 1,500 VA) = 1,500 VA

HEATING & COOLING LOADS - NEC 220.82(C)

(1) AC LOAD (0 VA X 100%) = 0 VA < < LARGEST
 (2) HEAT PUMPS NO SUPP (0 VA X 100%) = 0 VA
 (3) HEAT PUMPS (0 VA X 100%) = 0 VA
 SUPPLEMENTAL HEAT (0 VA X 65%) = 0 VA
 (4) ELECTRIC SPACE (0 VA X 65%) = 0 VA
 LESS THAN FOUR SEPARATELY CONTROLLED UNITS.
 (5) SPACE HEATING (0 VA X 40%) = 0 VA
 MORE THAN FOUR SEPARATELY CONTROLLED UNITS.
 (6) SPACE HEATING (0 VA X 100%) = 0 VA
 CONTINUOUS AT THE FULL NAMEPLATE VALUE.
 LARGEST HEATING OR COOLING LOAD 0 VA

RANGE (1 RANGE X 12,000 VA) = 12,000 VA

DRYER (1 DRYER X 5,500 VA) = 5,500 VA

NEUTRAL LOAD NEC 220.61

TOTAL SQ FOOTAGE (1,500 SQ FT X 3 VA) = 4,500 VA
 APPLIANCE CIRCUITS (2 X 1,500 VA) = 3,000 VA
 LAUNDRY CIRCUITS (1 X 1,500 VA) = 1,500 VA
 TOTAL CONNECTED NEUTRAL LOAD 9,000 VA
 FIRST 3,000 VA @ 100% (3,000 VA X 1.00) = 3,000 VA
 3,000-120,000 VA @ 35% (6,000 VA X 0.35) = 2,100 VA
 OVER 120,000 VA @ 25% (0 VA X 0.25) = 0 VA
 SUBTOTAL 5,100 VA

APPLIANCES FASTENED IN PLACE NEC SECTION 220.53

WATER HEATER (1 X 4,500 VA) = 4,500 VA
 FURNACE (1 X 7.2 A X 120 V) = 864 VA
 DISPOSAL (1 X 6.5 A X 120 V) = 780 VA
 DISHWASHER (1 X 11.2 A X 120 V) = 1,344 VA
 MIRCOWAVE (1 X 9.0 A X 120 V) = 1,080 VA
 CENTRAL VAC (1 X 12.0 A X 120 V) = 1,440 VA

RANGE DEMAND
 TABLE 220.55 COLUMN C
 70% OF TABLE 220.55 (8,000 VA X 0.70) = 5,600 VA

DRYER DEMAND
 TABLE 220.54
 70% OF TABLE 220.54 (5,500 VA 1.00 VA X 0.70) = 3,850 VA

UNBALANCED MISC LOADS 0 VA

NEUTRAL LOAD VA 14,550 VA

NEUTRAL LOAD (14,550 VA ÷ 240 V) = 61 A

FURTHER DEMAND FACTOR - NEC 220.61(B)(2)
 FIRST 200 A @ 100% (61 A X 1.00) = 61 A
 REMAINDER @ 70% (0 A X 0.70) = 0 A

MINIMUM NEUTRAL CONDUCTOR AMPACITY 61 A

MISC LOADS NEC 220.82(B)(4)

VOLTAGE DROP CALCULATIONS

(2 X 25' L X 0.1940 R X 86.0 A ÷ 1,000) = 0.8 VD
 (0.8 VD ÷ 240 V X 100) = 0.3 % VD

FAULT CURRENT CALCULATIONS

((22,000 AFC X 1.00 UA) + 0 MC) = 22,000 AFC
 (2 X 25 L X 22,000 AFC) ÷ (5,907 C X 1 N X 240 V) = 0.776 CF
 (1) ÷ (1 + 0.776 CF) = 0.563 CM
 (22,000 AFC X 0.563 CM) = 12,386 CLC

KEY

- A - Amps
- AFC - Available Fault Current
- C - Conductor Constance
- CF - Conductor Factor
- CLC - Conductor Let Through Current
- CM - Conductor Multiplier
- L - Length
- MC - Motor Contribution
- N - Number of Conductors
- R - Resistance
- UA - Utility Adjustment
- V - Volts
- VA - Volt Amps
- VD - Voltage Drop

TOTAL GENERAL LOAD 36,508 VA
 FIRST 10 KVA AT 100% 10,000 VA
 REMAINDER OF LOAD AT 40% 10,603 VA
 SUB TOTAL GENERAL LOAD 20,603 VA
 LARGEST HEATING OR COOLING LOAD 0 VA
TOTAL KVA 20,603 VA

TOTAL AMPS (20,603 VA ÷ 240 V) = 86 A

FUTURE AMPS (0%) 0 A

DESIGN AMPS 86 A

Prepared With Service Pro 2023 Software

Copyright Durand & Associates

www.durandassociates.com